December 11, 2025

Re: Campus Potable Water Treatment Services – IFB TAC 010726

Questions and Answers:

Below is a compilation of the questions received for this bid. Questions that were repeated, or of a recurring nature, were consolidated. Thank you very much for your interest.

1. **Question: Is there an auto notification/alarm/callout system in place for any failures in the plant?**

   Answer: Alarms are reported on the PLC for the equipment it controls and monitors.

2. **Question: Is chlorine bulk delivered to the side room? Are the operators required to move the day tanks for delivery, etc?**

   Answer: Chorine delivery is the responsibly of the contractor.

Respectfully,

Carol A Jacobs

Carol A. Davis Jacobs, CMS 1,
Contract Management Unit
(845) 877-6821 (Ext 3007)
(845) 877-3044 (fax)
carol.a.davisjacobs@opwdd.ny.gov